

REBUILD MASONRY JAMBS - INSTALL NEW SILLS

UNIT 2F
201

STAIR 2
102

UNIT 2E
202

UNIT 2D
203

UNIT 2C
204

UNIT 2B
205

UNIT 2A
206

NOTE: FLOOR/CLG ASSEMBLY ABOVE TO BE 2 HR RATED PER U.L.S.I. SYSTEM 4 ARE DESIGNATED WITH HATCHING

REMOVE EXIST. WD. TRIM, JAMB EXTENSIONS & FRAMING FROM EXIST. WINDOWS.

NOTE: COORDINATE DEMISING WALL LOCATIONS WITH EXISTING ROOF TRUSS LOCATIONS ABOVE

2 2X4 SKYLIGHTS IN JOIST SPACE (TYP) SEE STRUCTURAL FOR FRAMING.

EXIST. BEAM & EDGE OF LOFT ABOVE (SEE 2/A5 FOR LOFT PLAN)

WINDOW WELL ABOVE (SEE DETAIL)

REEROOF AREA W/ BASE SHEET AND 3 PLYS 20# FIBER GLASS FELTS SET IN HOT ASPHALT. MATCH EXISTING LEVEL AND SLOPE TO PREVENT PONDING. SEE DETAIL FOR REGID FLASHING AT ROOF/WALL INTERSECTION (SEE STRUCT. FOR FRAMING)

REBUILD MASONRY SILL

GARAGE ROOF

NEW GARAGE VENTILATION FAN (SEE MECH)

FIRE SHUTTER AT CORRIDOR WINDOWS, TYP.

SEAL JOINTS BETWEEN WALL AND ROOF WITH ROOFING CEMENT, TYPICAL.

REBUILD MASONRY SILL

REPAIR ROOF AS REQ'D (SEE SITE/ROOF PLAN)

REMOVE EXIST. WD. TRIM, JAMB EXTENSIONS & FRAMING. REBUILD MASONRY SILL

LEGEND:

-  EXISTING CONSTRUCTION
-  NEW CONSTRUCTION
-  NEW 1 HOUR RATED CONSTRUCTION
-  NEW 2 HOUR RATED CONST.
-  FIRE EXTINGUISHER CABINET SYMBOL
-  WALL TYPE DESIGNATION



1 SECOND FLOOR PLAN

A5 SCALE: 1/8" = 1'-0"